Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran, South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346

Email: Firecustomerservices@eaton.com

Web: www.eaton.com



DECLARATION OF PERFORMANCE

No DoP0002b

Unique identification code of the product-type:		
Symphoni LX Wall Base WP		
Intended use/es:		
Fire detection and fire alarm systems		
Manufacturer:		
Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom		
Authorised representative:		
Not Applicable		
System/s of AVCP:		
System 1		
Harmonised standard/s:		
EN54-23:2010		
Notified body/ies:		
AFNOR Certification, 11 rue Francis de Pressensé, FR – 93571, La Plaine Saint-Denis, Cedex, France (0333-CPR-075446)		

Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran, South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346

Email: Firecustomerservices@eaton.com

Web: www.eaton.com



Declared performance/s:

Essential Characteristics	ential Characteristics Performance	Harmonized Technical Specification
		EN54-23:2010
Performance under fire conditions	Pass	4.3.1 to 4.3.7
Operational reliability	Pass	4.2.1 to 4.2.8
Durability Temperature Resistance	Pass	4.4.1.1 to 4.4.1.3
Durability Humidity Resistance	Pass	4.4.2.1 to 4.4.2.3
Durability Corrosion Resistance	Pass	4.4.4
Durability Shock and Vibration Resistance	Pass	4.4.3.1 to 4.4.3.4
Durability Electrical Stability	Pass	4.4.5

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for an on behalf of the manufacturer by:

Name: Mr Philip Williams (Approvals Manager)

Signed: PJ Www.

Place: Cwmbran Date: 15th July 2019