Intertek Intertek Intertek Intertek Intertelo inter

Certificate of Constancy of Performance





In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): BiWire Ultra Input/Output Units

(refer to attached appendix for details and conditions)

placed on the market under the name or trade mark of: Cooper Lighting & Safety Limited

Wheatley Hall Road, Doncaster, DN2 4NB, United Kingdom

and produced in the manufacturing plant(s): Cooper Fulleon Limited (CPRCOOUK.01)

Llantarnam Park, Cwmbran, NP44 3AW, South Wales

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN54-18:2005+AC:2007

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on **10 December 2015** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body 0359

Intertek Testing & Certification Limited

Cleeve Road, Leatherhead Surrey, KT22 7SB

Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977 E-mail: cpd.uk@intertek.com Gordon Ash
Certification Manager

Date 10/12/2015

Issue '

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance 0359-CPR-00449



Appendix to Certificate of Constancy of Performance 0359-CPR-00449

The details and conditions of use for the BiWire Ultra Input/Output Units, placed on the market under the name or trade mark of:

Cooper Lighting & Safety Limited

Wheatley Hall Road, Doncaster, DN2 4NB, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

Products compliant with EN54-18:2005+AC:2007

Product Variant	Manufacturing Location	Description
BWEXTR24V	CPRCOOUK.01	BiWire Ultra 24V Relay Unit
BWEXTR230V	CPRCOOUK.01	BiWire Ultra 230V Relay Unit

Conditions of use:

Suitable for indoor applications.

The BWEXTR24V and BWEXTR230V are only suitable for use with the BiWire Ultra Control and Indicating Equipment, which have been approved for use with the EOLM-3 BiWire Ultra End-of-Line Module.

General Notes:

- 1. Evaluated under Intertek project number 102059227.
- 2. <u>No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.</u>

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00449 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

Certificate of Constancy of Performance 0359-CPR-00449



Appendix to Certificate of Constancy of Performance 0359-CPR-00449 (continued)

Table of performance for EN54-18:2005+AC:2007 Harmonised technical specification			
Response delay (response time)	Pass	5.2	
Performance under fire conditions	Pass	5.1.4	
Operational reliability	Pass	5.1.4	
Durability of operational reliability temperature resistance	Pass	5.3, 5.4	
Durability of operational reliability; vibration resistance	Pass	5.8 to 5.11	
Durability of operational reliability; humidity resistance	Pass	5.5, 5.6	
Durability of operational reliability; corrosion resistance	Pass	5.7	
Durability of operational reliability; electrical stability	Pass	5.2, 5.12	

Note:

For details relating to performance conditions and associated clauses which are applicable to the product(s) under test, refer to Intertek test report 102059227LHD-011.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00449 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom